

HAZARDOUS WASTE DETERMINATION & DISPOSAL REPORT

**84-939 NOHOLIO ROAD
WAIANAE, HI 96792**

Prepared for:

**RYSE
PO Box 11662, 41
Honolulu, Hawaii 96828**

Prepared by:

**Prometheus Construction
651 Komohana Street
Kapolei, HI 96707**

Date of Issuance:

May 23, 2025

Timeline of Determination of Non-Hazardous Waste

April 15, 2025: Site boundaries at demolition site set with fencing. Dust control established and maintained via misting. All demolition employees outfitted with P100 respirators. Structure demolished and inserted into 40 cubic yard roll off bin. All visible demolition materials recovered in bin. Bin covered with plastic wrap and stored at Prometheus PASHA yard for testing.

May 8, 2025: Prometheus Construction gathered and collected a 30-part multi-incremental sample representing the entirety of the waste stream from the demolished home located at 84-939 Noholio Road (Attachment A). Samples taken from a 40 yard roll off bin with demo waste inside.

May 9, 2025: Sample was taken to Advanced Analytical Laboratory for TCLP test. Test results came in below the hazardous waste threshold determining that the waste stream is non-hazardous (attachment B).

May 14, 2025: Clearance ticket was requested and material testing report sent to PVT (attachment C).

May 19, 2025: Clearance ticket issued by PVT (attachment C).


May 21, 2025: Material was dumped at PVT as evidenced by the attached dump tag (attachment D).

Hazardous Waste Determination Checklist

Step	Response	Comments
1. Is material is a solid waste? (HAR §11-261-2)	Yes	
2. Is waste excluded? (HAR §11-261-4)	No	
3. Is waste listed? (F, K, P, U lists) (HAR §11-261-30 to §11-261-33)	No	
4. Waste have hazardous characteristics? (HAR §11-261-21 to §11-261-24)	Yes	See Aina Environmental report
5. §11-261-24 TCLP Results define waste as Hazardous?	No	See attached waste stream TCLP Results
6. Document the waste determination (HAR §11-262-11)	N/A	Waste stream is non-hazardous
7. Manage the waste according to determination	N/A	Clearance ticket and tags attached

84-939 NOHOLIO ROAD DEMOLITION WASTE STREAM SAMPLING LOCATIONS

BIN SAMPLE	MATERIAL SAMPLED	LOCATION
A1	aluminum corrugated	Top level
A2	dimensional lumber	Top level
A3	painted wood	Top level
A4	painted wood	Top level
A5	dimensional lumber	Top level
A6	plywood	Top level
B1	plywood	mid-level 1
B2	plywood	mid-level 1
B3	painted wood	mid-level 1
B4	painted wood	mid-level 1
B5	painted T&G wood	mid-level 1
B6	dimensional lumber	mid-level 1
C1	dimensional lumber	mid-level 2
C2	painted wood	mid-level 2
C3	painted wood	mid-level 2
C4	gravel	mid-level 2
C5	plywood	mid-level 2
C6	dimensional lumber	mid-level 2
D1	dimensional lumber	mid-level 3
D2	soil	mid-level 3
D3	gravel	mid-level 3
D4	brick	mid-level 3
D5	soil	mid-level 3
D6	painted wood	mid-level 3
E1	soil	Lower level
E2	gravel	Lower level
E3	gravel	Lower level
E4	concrete	Lower level
E5	concrete	Lower level
E6	concrete	Lower level





12524 130th Lane NE
Kirkland WA 98034

Tel: (425) 214-5858
(425) 214-5868
Email: lisa@accu-lab.com
website: www.accu-lab.com

Analytical Report

Client	Advanced Analytical Laboratory 544 Ohohia Street #10 Honolulu, HI, 96819	Acculab WO#	25-AL0513-4
Project Manager	Uwe Baumgartner/ Elisa Young	Date Sampled	5/8/2025
Project Name	Noholio House Demo	Date Received	5/13/2025
Client Project#		Date Reported	5/14/2025
Project#	AA306		

Metals in Soil TCLP by EPA 6020B/3010A/1311

Accu Lab Batch# AL051325-10

Client sample ID					TCLP A-1	TCLP MS	TCLP MSD	TCLP RPD
Lab ID	MRL	Unit	MTH BLK	LCS	25-AL0513-4-1	25-AL0508-2-1	25-AL0508-2-1	25-AL0508-2-1
Matrix			TCLP Extract	TCLP Extract	TCLP Extract	TCLP Extract	TCLP Extract	TCLP Extract
Date Extracted			5/13/2025	5/13/2025	5/13/2025	5/13/2025	5/13/2025	5/13/2025
Date Analyzed			5/14/2025	5/14/2025	5/14/2025	5/14/2025	5/14/2025	5/14/2025
Arsenic (As)	0.05	mg/l	nd	102%	nd	93%	96%	3%
Barium (Ba)	0.50	mg/l	nd	107%	0.65	107%	111%	4%
Cadmium (Cd)	0.05	mg/l	nd	102%	nd	91%	92%	1%
Chromium (Cr)	0.50	mg/l	nd	92%	nd	95%	92%	3%
Lead (Pb)	0.05	mg/l	nd	99%	nd	92%	95%	3%
Selenium (Se)	0.05	mg/l	nd	113%	nd	94%	94%	0.5%
Silver (Ag)	0.05	mg/l	nd	89%	nd	93%	94%	1%
Mercury (Hg)	0.05	mg/l	nd	86%	nd	108%	106%	2%

Acceptable Recovery Limits:

LCS	80-120%
MS/MSD	75-125%
Acceptable RPD limit:	20%

This report is issued solely for the use of the person or company to whom it is addressed.
Any use, copying or disclosure other than by the intended recipient is unauthorized.

Address: 544 Ohohia St., Unit 10 Honolulu, HI 96819

TURNAROUND TIME:

Phone: (808) 836 2252

Address: 544 Ohohia St., Unit 10 Honolulu, HI 96819

-AX306

[illegible]

Request for Clearance Number

All Clearance Numbers expire 6 months from date of approval. Customers should renew their clearance number or request an extension prior to the expiration date. Clearance Numbers are issued during business hours, Monday through Friday only.

Part I. Customer Information

Jobsite Address 84-939 Nohiio Road Waiānae, Hawaii, 96792		Name of Property Owner RESIDENTIAL YOUTH SERVICES & EMPOWERMENT		Name of Demolition Contractor Prometheus Construction	
Address 651 KOMOHANA ST Kapolei, HI, 96707	Phone Number (808) 591-1141	Fax Number	Email peter@prometheusconstruction.com	P.O. #	Job # Nohollo Demo

Name of Transporter Prometheus Construction	Phone Number (808) 591-1141	Fax Number	Email peter@prometheusconstruction.com
---	---------------------------------------	-------------------	--

Bill Charges To Prometheus Construction	Authorized Signature 	Title Cliff Tillotson VP	Date 05/14/2025
---	--	------------------------------------	---------------------------




Use of Site Residential	Job/Project Demolition	Waste Material (check one per form) Mixed Waste
-----------------------------------	----------------------------------	---

Part II. Waste Certification

1. This waste is not a "Hazardous Waste" as defined by EPA or the State of Hawaii.
2. This waste does not contain regulated radioactive materials or regulated concentrations of PCBs (Polychlorinated Biphenyls).
3. The statements and attachments contain true and accurate descriptions of the waste. All relevant information regarding known or suspected hazards in the possession of the undersigned has been disclosed.
4. The analytical data presented herein or attached hereto were derived from testing representative samples taken in accordance with the DOH HEER Technical Guidance Manual.
5. If any changes occur in the character of the waste, the undersigned shall notify a Landfill representative immediately.
6. The waste is not generated from a CERCLA site.

Terms and Conditions

Accepted

Property Owner or Authorized Agent Signature 		Demolition Contractor or Authorized Agent Signature 		Transporter or Authorized Agent Signature 	
Title Cliff Tillotson - VP	Date 05/14/2025	Title Cliff Tillotson VP	Date 05/14/2025	Title Cliff Tillotson VP	Date 05/14/2025

FOR OFFICE USE ONLY

Clearance No. : ☐ Approved ☐ Declined Initials _____ Date _____

☐ Landfill and ☐ Phase I or Phase II

Issued By _____ Date: _____

Compuweigh Entry By: _____ Date: _____

Comments:

Filed By: _____

PVT LAND COMPANY, LTD.
87-2020 Farrington Hwy.
Waianae, Hawaii 96792
Ph: (808)668-4561 Fax:(808)668-1368

Approval Date: 5/19/2025

Bill To: PROMETHEUS CONSTRUCTION

Fax No.: (808) 591-1153

Clearance No: 151417 Expiration Date: 11/19/2025

The Clearance Number above has been assigned to you for the following Job Site:

84-939 NOHILIO ROAD WAIANAE

Material: MIXED WASTE / DEMO

PO Number:

Job Number: NOHOLLO DEMO

The following haulers are listed for this job site:

PROMETHEUS CONSTRUCTION

Please submit a "Transporters Authorization" form to add any additional haulers not listed above.

PLEASE HAVE YOUR DRIVERS OR HAULERS USE THIS CLEARANCE
NUMBER TO ENTER THE LANDFILL.
THANK YOU FOR YOUR COOPERATION.

PVI LAND COMPANY LTD.
87-2020 FARRINGTON HWY.
WAILANAE, HI 96792

Ticket #: 1328988

Bill To: CREDIT CARD CUSTOMERS
Haul Acct/Veh #: PROMCO /PROMC 830
PO/Job #: NODULO DEMO
Date: 05/21/25 Time 1/0:10:05 AM/10:46 AM
Clr #: 151417 - Nihilio Road 04 939 Wailanae

Materials: Mixed Waste/Demo
Gross: 44740 Tare: 27760 Net: 16980 lbs
0.49 Tons @ 80.00/TK \$ 679.20
Fees: 0.00

Tax	32.00
TOTAL	711.20

Customer: 1725 - PROMOCUS CONSTRUCT
Notes:

STATE OF HAWAII CERTIFICATE OF MEASUREMENT
DIVISION OF MEASUREMENT STANDARDS

This certifies to the accuracy and
identity of the quantity & commodity
shown, is suitable for all deliveries
when sealed by a measurer/master.

STATE OF HAWAII MEASUREMENT MASTER
NO. Ashley Meyer Registered Int'l's MM

Print Type: 5 - Credit Card (VISA/MC)
Fee codes: